

GOVERNMENT OF MAHARASHTRA

Out No. : MFS/51/2020/707
Tel No. 2667 7555
Fax No.2667 7666

Directorate of Maharashtra Fire Service
Maharashtra Fire Service Academy, Vidyanaagri,
Hans Bhugra Marg, Santacruz (East), Mumbai - 400 098
Date: 24/12/2020

To,
M/s. Shri. Vithalrao Joshi Charities Trust,
G.No.4047, 2916, 2920, S.No.-1372, 1479, 1486,
At-Kasarwadi, Tal-Chiplun,
Dist-Ratnagiri.

Sub:- Revalidation of "Provisional No Objection Certificate"
for your Proposed Educational Building On
G.No.4047, 2916, 2920, S.No.-1372, 1479, 1486, At-Kasarwadi, Tal-
Chiplun, Dist.-Ratnagiri.

Ref.:- 1) This Office Prov. Noc No.MFS/52/2016/147. Dated-02/03/2016.
2) Your application Vide No. Nil, Dated:-09/12/2020.

With reference to Sr. no.01 above we had issued a "Provisional No-Objection Certificate" to M/s. Shri Vithalrao Joshi Charities Trust, for their proposed Educational Building on above mentioned address.


With reference to Sr no.01 above, this office revalidate your Provisional No-Objection Certificate for further period of One Year i.e. up to 23.12.2021. You are hereby informed that no further extension will be granted on any ground, which may please be noted.

You are hereby informed to comply with the recommendations mentioned in this office Provisional No-Objection Certificate vide.No.MFS/52/2016/147 scrupulously and after compliance of the same an inspection will be carried out and after satisfactory compliance, Final No-Objection Certificate will be issued.

The undersigned reserves right to amend/suggest any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the buildings.

Thanking you.

Yours faithfully


A.V. Parab


Nominated Officer
Maharashtra Fire Service.





Principal

Shri Vithalrao Joshi Charities Trust's
English Medium Secondary School, Sawarde,
Tal. Chiplun, Dist. Ratnagiri. Pin- 415606



School Director

Shri Vithalrao Joshi Charities Trust's
English Medium School & Junior College of Science
Sawarde, Tal. Chiplun, Dist. Ratnagiri. Pin 415606

Form B

Ref No: - MTPL/2022/05

{See section 3(3) and 4(2)}

Six monthly certificates to be given in every January and July by the owner or the occupier for compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

Certified that I/ We have carried our inspection of the Fire Prevention and Life Safety Measures installed in the following building or premise namely: -

Education Complex of Shri. Vithalrao Joshi Charities Trust

AT VILLAGE-KASARWADI., TAL. CHIPLUN DIST. RATNAGIRI: 415606

TYPE: Fire Hydrant System | Fire Extinguisher Systems.

I/We further certify that these installations in the above-mentioned buildings are maintained in good repair and efficient condition during the period **1st January 2022 to 30th June 2022** as required Under the Provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah-III of 2007). The details of the inspection of installations carried out by me / us are mentioned in the report appended herewith.

Place: - Ambarnath (East)

Date: - 27.05.2022

SHAILESH GHANSHAM SAWANT

Digitally signed by SHAILESH GHANSHAM
SAWANT

Date: 2022.05.27 18:42:21 IST

Location: MAI TECH PRIVATE LIMITED

Signature and Address of the Licensed Agency

License No: MFS/ LA/ RF-245/ RD-238 / P- 54

ANNEXURE 1

Ref No: - MTPL/2022/05

Below Mentioned items are checked and found in good working conditions.

Site Address:

Education Complex of Shri. Vithalrao Joshi Charities Trust

AT VILLAGE-KASARWADI, TAL. CHIPLUN DIST. RATNAGIRI: 415606

| SR.NO | PARTICULARS | QUANTITY [No.] |
|----------|---------------------------------|-----------------|
| A | Fire Hydrant System | |
| 1 | Booster Fire Pump | 01 |
| 2 | Terrace Water Tank | 5000 ltr. |
| 3 | STARTER | 01 |
| 4 | Hose Reel Drum Complete Set | 12 |
| 5 | SS Hydrant Valves ISI | 03 |
| 6 | Single door hose box Set | 03 |
| 7 | Double door hose box Set | 01 |
| 8 | Butterfly Valve 80mm | 03 |
| 9 | NRV 80 mm | 02 |
| 10 | 2 Way Inlet | 01 |
| 11 | 20 mm ball valve | 17 |
| 12 | Air release valve | 04 |
| B | EXTINGUISHERS | |
| 1. | Fire Extinguisher CO2 3.2 kg | 04 |
| 2. | Water CO2 Store Pressure 9 Ltr. | 02 |
| C | Signage Board | 12 |

Note: - This is to certify that we have inspected the above Fire Fighting System installed at above Premises.

We also certify that the Performances of the above equipment's working Satisfactory.

Place: - Ambernath (East)

Date: - 27.05.2022

SHAILESH GHANSHAM SAWANT

Digitally signed by SHAILESH
 GHANSHAM SAWANT
 Date: 2022.05.27 19:18:50 IST
 Location: MAI TECH PRIVATE LIMITED

Signature and Address of the Licensed Agency

License No: MFS/ LA/ RF-245/ RD-238 / P- 54



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14]
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-245 / RD-238 / P-54

Date: 05.05.2022

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Mai Tech Pvt Ltd.,** having their registration office at **F-4, E Wing, Udyog Bhavan No. 02, Addl MIDC, Ambernath (E), 421 506** and their contact details are Office Number: 8879117477 and Email ID: info@maitech.co with TAN registration No. AAHCM1498C and GST No. 27AAHCM1498C1ZF to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- | | |
|--|----------------|
| 1. Fire Fighting and Sprinkler System: | Class C |
| 2. Detection and Fire Suppression System: | Class D |
| 3. Passive System: | Class D |

M/s. Mai Tech Pvt Ltd., shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **05.05.2022 to 04.05.2023**

Hatyal
Kiran
Asst Director

Digitally signed
by Hatyal Kiran
Date: 2022.05.11
23:17:21 +05'30'

SHAILESH GHANSHAM SAWANT Digitally signed by SHAILESH GHANSHAM SAWANT
Date: 2022.05.11 20:04:24 +05'30'

SANTOSH
SHRIDHAR
WARICK

Digitally signed by
SANTOSH SHRIDHAR
WARICK
Date: 2022.05.12
10:48:09 +05'30'

(S S Warick)
Director

Maharashtra Fire Service

Digital Signature of License Holder

Note:

* in lieu of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.

This license has been issued under the provisions in section 9 (5) and section 18 (2) and is valid in all Local Authorities as defined in section 2 (7) & Planning Authorities as defined in section 2(12) of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006.

1. The licence shall be :-
 - a) Non-transferable
 - b) Valid for one year from the date of issue, unless suspended or cancelled earlier.
 - c) Renewable, if so desired, before expiry of the licence.

2. Changes, if any. In respect of the –
 - a) Partners, Directors or Members
 - b) Address of the office of the License AgencyShall be forthwith reported to the Directorate of Maharashtra Fire Service.

3. The Licensed Agency shall always keep the work executed or being executed, open for inspection by the Director, or any Fire Officer authorized by the Director.

4. The Licensed Agency shall issue a certificate in Form “A” to the client in respect of the works executed by them and shall issue a six monthly certificate in Form –“B”, in every January and July after carrying out inspection of the Fire Prevention and Life Safety Measures work executed, being executed by them is in good repair and efficient conditions at all times.



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in